

# RIGHT-OF-WAY (ROW) SPECIFICATIONS

It is your responsibility to obtain any required easements and to clear the ROW path to SVEC specifications before lines can be constructed. The ROW shall be 30 feet wide along the approved path of the primary line. Additional easements may be required from other property owners along the path.

- ▶ All vegetation must be cut or trimmed a minimum of 15 feet on both sides of the path staked for the line and poles.
- ▶ Tree stumps must be cut to ground level.
- ▶ ROW must be cut ground to sky with no overhang into the 30-foot easement.
- ▶ No plants or trees can be planted in the ROW.
- ▶ If property is fenced, a 12-foot gate must be provided for SVEC to gain access to the property to maintain the power line. SVEC will provide a lock for its employees to enter the property.
- ▶ After they are cleared, rights-of-way must be inspected and approved by SVEC.

